User instructions ClimaRad S-Fan+ (delivery until 2022)

Operation of the ClimaRad S-Fan+

⚠ **Please note! The air supply opening must always remain open and unimpeded!**

Operation ClimaRad S-Fan+

The ClimaRad S-Fan+ can be operated by using the control panel on the underside of the device.

Control panel

Function keys

AUTO

▶

Automatic control. The room ventilation is controlled automatically by your ClimaRad S-Fan+, which ventilates on the basis of CO_2 and RH measurements.

➕ ➖

Manual: manual ventilation using outside air:
You can set your desired ventilation speed with the + and – keys on the control panel. After a period of 8 hours, the ClimaRad S-Fan+ will switch back to the automatic setting. Use this function for example when you want to lower the temperature in your bedroom by a few degrees at night in the summer (summer night ventilation).

⏸

Pause/Off. Use this function if you (temporarily) do not want to ventilate. After a period of 4 hours, the ClimaRad S-Fan+ switches back to the automatic setting. When the button is pressed for 5 seconds, the unit switches off. In case of emergencies you can use this function to switch off the device.

Comfort mode. The ClimaRad S-Fan+ will pre-heat the external air to 12°C. After a period of 4 hours, the ClimaRad S-Fan+ will switch back to the automatic setting.

Heating. By switching this function on, the ClimaRad S-Fan+ will heat the room. After a period of 2 hours, the ClimaRad S-Fan+ will switch back to the automatic setting.

The duration can be selected with   ➖ • • • • • ➕
the + and – keys on the control panel .   1 2 3 4 5 hours

Child lock. The child lock will be activated when you press and hold the three buttons on the panel for 4 seconds.

Messages | Switch off

🔒

Child lock. The child lock is switched on. Press and hold the three buttons for 4 seconds to switch it off.

Press 4 seconds simultaneously

✗

Malfunction. A malfunction has occurred. Contact your technician or housing corporation.

filter vervuild

Dirty filter. Replace the air filter or contact your technician or housing corporation. After replacement, press and hold the + and – buttons for 6 seconds.

Press for 6 seconds

📶

Pairing. The ClimaRad S-Fan+ can be linked to other ClimaRad products. Press the buttons briefly and simultaneously.

Press briefly and simultaneously